

6

5

4


3

2


1

REV/NO	REV.	TANIM-DESCRIPTION	TARİH- DATE	ONAY-APPROVED BY
02	A	Weight Information is added.	24.01.2020	


REVIZYONLAR-REVISIONS




Bottom View



Three-legged for
100-500 liters.




Front View




C-C

N CODE	DESCRIPTION	CONNECTIONS				
		100	160	200	300	500
N1	Water Inlet-Outlet Connections for Primary-Secondary Route	1"	1 1/2"	1 1/2"	1 1/2"	1 1/2"
N2	Cleaning Flange	4"	4"	4"	4"	4"
N3	Thermometer and Sensor Connections	1/2"	1/2"	1/2"	1/2"	1/2"
N4	Electric Heater Connection	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"
N5	Magnesium Anode Connections	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"
N6	Drain Connection	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"



Isometric View

Øtank	ØInsulation	Insulation Type	ENAMELLED ACCUMULATION TANK DIMENSIONS							NET WEIGHT (Kg)		
			L1	L2	L3	L4	L5	L6	L7		H	
100	Ø380	PU	50	260	465	670	875	315	570	1085	1110	42
160	Ø480	PU	50	265	470	675	880	320	575	1110	1135	60
200	Ø480	PU	50	250	530	810	1090	315	670	1315	1340	71
300	Ø480	PU	50	275	715	1155	1595	330	935	1845	1860	82
400	Ø600	PU	50	275	495	715	940	355	605	1195	1220	75
500	Ø640	PU	50	320	720	1120	1520	375	920	1820	1845	115



Top View

General Tolerances - General Tolerances	AÇIKLAMA- DESCRIPTION		Çizen- Drawn By	I. KARAKOÇ	Tolerans- Tolerance Table	General Tolerance Table
Uzunluk Ölçülerti- Linear Dimensions	ENAMELLED ACCUMULATION TANK 100-500 L		Kontrol-Check By	A. ORAK		
1 up to 400	±10		Resin No-Draw No	000021A2		
400 up to 1000	±20		Drın No-Product No	KAT		
1000 up to 3500	±30		Malzeme- Material			
			Sayfa-Sheet	A4		
			Y.Tarih-Date	30.10.2019		
			Agrlık - Weight			
			Referans Doküman No-Reference Document No			

KODSAN

BU RESMİN BİTİRİM HAKKINDA KODSAN A.Ş. AÇIKTIR. TAKLİT EDİLEMEZ. İZİNSİZ ÇİĞAL TILAMAZ. RESİM ÖZGERİNDEN ALIĞI ALMAVIZ. ALL RIGHTS OF THE DRAWING BELONG TO THE KODSAN WATER HEATER CONSTRUCTION IND. TRADE INC. CANNOT BE COPIED WITHOUT PERMISSION

6

5

4

3

2

1